

MUNICIPAL CORPORATION OF DELHI
OFFICE OF DY HEALTH OFFICER
SOUTH ZONE GREEN PARK, NEW DELHI-110016
dhosouthzone@gmail.com

No.DHO/SZ/MCD/2023/.D.....951

Date:13.7.23

HEALTH CERTIFICATE

Name of the school: SANT NIRANKARI PUBLIC SCHOOL

Address of School: T-23, Malviya Nagar, (Khirki Village Road), New Delhi-110017

No. of Shifts: One Timing: Morning

No. of Students: Boys: 360, Girls: 242, Total : 602

No. of Staff (Teachers): Ladies: 32, Male: 11, Total : 43


That the accommodation provided for the class rooms as calculated.

- | | |
|--|-----|
| 1. (A) On floor space is sufficient | Yes |
| (B) On Cubic space is sufficient | Yes |
| 2. That the classrooms are well ventilated | Yes |
| 3. That the classrooms are kept Neat and clean | Yes |
| 4. That the classrooms are well lighted | Yes |

That the building is not in substantial repair in the class of NIL

- | | |
|---|-----------|
| 5. That the drinking water is wholesome | Wholesome |
| 6. That the latrines arrangement is adequate and there are sufficient latrines. | |
| 7. That urinals arrangement is adequate and there are sufficient urinals | |

This certificate is issued for sanitary and hygienic condition from health point of view of the school premises. This certificate has no bearing structure stability and fire safety. This certificate is valid for one year from the date of issue.


Dy. Health Officer
- South-Zone
Dr. Deepak Mittal
Dy. Health Officer/SZ



Vice Principal
Sant Nirankari Public School
(Recognised)
T-23, Khirki Village Road
Malviya Nagar, New Delhi-110017


Chairperson
Sant Nirankari Public School
(Recognised)
T-23, Khirki Village Road
Malviya Nagar, New Delhi-110017



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



स्वच्छ भारत
एक कदम स्वच्छता के ओर

Ref. A.C.W.A.(South):- Paid/2023-24/P1-2/Challan no 383 Dt 20.03.2023

S. No 8054

Date: 25.04.2023

M/S SANT NIRANKARI PUBLIC SCHOOL
T-23, MALVIYA NAGAR (KIIRKI VILLAGE RD)

NEW DELHI-110017

Date of Sample collection :- 18.04.2023

S.No	Characteristics	Unit	Acceptable Limit	Permissible Limit	Test Method	UG TANK NEAR OFFICE	TAP DRINKING POINT NEAR MATH'S LAB.
1.	Clarity	Unit	5	15	IS 3025 Part-4	Clear	Clear
2.	Odour	---	Agreeable	Agreeable	IS 3025 Part-5	Agreeable	Agreeable
3.	Turbidity	NTU	1	5	IS 3025 Part-10	1.68	1.08
4.	pH Value	---	6.5-8.5	No relaxation	IS 3025 Part-11	7.4	7.5
5.	Conductivity	µmho/cm ²	---	---	---	713	735
6.	Total Dissolved Solids	mg/L	500	2000	IS 3025 Part-16	464	478
1.	Phenolphthalein Alkalinity	mg/L	---	---	---	NIL	NIL
2.	Total Alkalinity (as CaCO ₃)	mg/L	200	600	IS 3025 Part-23	144	146
3.	Total Hardness (as CaCO ₃)	mg/L	200	600	IS 3025 Part-21	242	248
4.	Carbonate hardness	mg/L	---	---	---	144	146
5.	Non- Carbonate Hardness	mg/L	---	---	---	98	102
6.	Calcium Hardness	mg/L	---	---	---	138	138
7.	Magnesium Hardness	mg/L	---	---	---	104	110
8.	Ammonia (as Total N)	mg/L	0.5	No relaxation	IS 3025 Part-34	ND	ND
9.	Nitrite (as N)	mg/L	---	---	---	ND	ND
10.	Nitrate	Mg/L	---	45.0	IS 3025 Part-34	37.5	40.0
11.	Sulphate (as SO ₄)	mg/L	200	400	IS 3025 Part-24	64	64
12.	Chloride (as Cl)	mg/L	250	1000	IS 3025 Part-40	72	74
13.	Iron	Mg/l	---	1.0	IS 3025 Part-53	0.06	0.06
14.	Fluoride	mg/L	1.0	1.5	IS 3025 Part-60	0.28	0.28
15.	Calcium (as Ca)	mg/L	75	200	IS 3025 Part-57	55.2	55.2
16.	Magnesium (as Mg)	mg/L	30	100	IS 3025 Part-46	24.96	26.4
17.	Free Residual Chlorine	mg/L	0.2	1	IS 3025 Part-26	0.25	0.25

REMARKS :- AS PER BIS-10500:2012 On the basis of tested parameters the both sample result are within permissible limit, Subject to Bacteriological satisfactory report.

ACWA(SOUTH)
Assistant Chief Water Analyst
Copy Delhi Jal Board (A Govt. of Delhi)
1 CVWWS
2013 PLaboratory (South)
2 Office Copy
W.W. Okhla New Delhi - 110 025

CHEMIST

ACHEMIST




Vice Principal

Sant Nirankari Public School

Chairperson

Sant Nirankari Public School

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

 Delhi Jal Board	DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL ZONAL LABORATORY (SOUTH) WATER WORKS OKHLA DELHI-110025	 हर शयनं शत्रुणो वीर्यं
 LICENCE No- CRO/QML-8004290 IS/ISO 9001:2015		

Dated:26.04.2023


No. DJB/DTQC/ CWA (W&S)III / ACWA (south)/ Bact/P.S./2023-2024/002-003/18.04.2023


Bacteriological Analysis Report as per IS 10500:2012


To Sant Nirankari Public School T-23 ,Malviya Nagar New Delhi -110017	Party Ref.No./Date: SNPS/MN/2022-2023/236/Dt:27.02.2023 Deptt.Challan No. /date: 383/20.03.2023 Dt.of sample collection: 18.04.2022 No. of Sample: Two(02) Collected by: Name- Sh. V.P Singh Desig.- Bacteriologist
---	--

SL.No.	Particulars	Clarity	Residual chlorine	Total coliform/ E.coli in 100 ml sample
1.	UG Tank Near Office in Campus Of School	Clear	0.25	0
2.	Tap Drinking Point Near Maths Lab	Clear	0.25	0


RESULT:- Collected water sample(s) as mentioned above at Sr.No. 1&2 were found bacteriological satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.


 23/4/23
ACWA (SOUTH)


 26/04/2023
BACTERIOLOGIST(SOUTH)


 26/04/23
ASST/BACT.

Assistant Chief Water Analyst
 Delhi Jal Board (A Govt. of Delhi)
 Zonal Laboratory (South)
 W.W. Okhla New Delhi - 110 025


Vice Principal
Sant Nirankari Public School
 (Recognised)
 T-23, Khirki Village Road
 Malviya Nagar, New Delhi-110017


Chairperson
Sant Nirankari Public School
 (Recognised)
 T-23, Khirki Village Road
 Malviya Nagar, New Delhi-110017